




Calibration of a Pressure Transducer

PROBLEM

The pressure of a critical process is to be monitored by a computer. To ensure accuracy and reliability, attention has to be paid to the entire system calibration. How can the pressure system be calibrated using the internal calibration resistor of the pressure transducer?

SOLUTION

The **API 4051 G M02** Strain Gauge (Bridge) Input to DC Transmitter module provides the stable excitation voltage for the pressure transducer and produces the required 0-10 VDC output for the computer.



The API 4051 G M02 utilizes the pressure transducer's internal calibration resistor to unbalance the bridge to a specified value when the test switch is in the CAL position, ensuring accurate system calibration.



Did You Know...?

All Api plug-in and DIN style modules are covered by a LIFETIME WARRANTY.