

## **USER MANUAL**

**ZLine** 



## Z109REG2-1

Universal converter module with galvanic isolation

Chapter index	Page
1. Preliminary warnings	2
<ul><li>2. Description and characteristics</li><li>2.1 Module description</li><li>2.2 General characteristics and features</li></ul>	2
3. Technical specifications 3.1 Input 3.2 Outputs 3.3 Connections 3.4 Power supply 3.5 Module case 3.6 Environmental conditions	2
4. Preliminary instructions for use	4
<ul> <li>5. Electrical connections</li> <li>5.1 Safety measures before use</li> <li>5.2 USB interface</li> <li>5.3 Connections</li> <li>5.4 Power supply</li> <li>5.5 Universal input</li> <li>5.6 Analog and relay output / strobe input</li> </ul>	4
<ul> <li>6. Configuration</li> <li>6.1 Input selection / Measuring scale</li> <li>6.2 START and END settings</li> <li>6.3 Output selection</li> <li>6.4 Configuration through a PC</li> <li>6.5 Jumper positions</li> <li>6.6 LED indications on the front panel</li> </ul>	5
7. Purchase order code	8
8. Module layout	8
9. Decommissioning and disposal	8









#### SENECA s.r.l.

Via Austria, 26 – 35127 – PADOVA – ITALY

Tel. +39.049.8705355 - 8705359 Fax. +39.049.8706287

Internet site: www.seneca.it Technical assistance: support@seneca.it

Commercial reference: sales@seneca.it

This document is property of SENECA srl. Duplication and reproduction of it are forbidden (though partial), if not authorized. Contents of present documentation refers to products and technologies described in it. Though we strive for reach perfection continually, all technical data contained in this document may be modified or added due to technical and commercial needs. It's impossible eliminate mismatches and discordances completely. Contents of present documentation is anyhow subjected to periodical revision. If you have any questions don't hesitate to contact our structure or to write us to e-mail addresses as above mentioned.



#### 1. PRELIMINARY WARNINGS

Before carrying out any operation it's mandatory to read all the content of this user Manual. Only electrically-skilled technicians can use the module described in this user Manual.

Only the Manufacturer is authorized to repair the module or to replace damaged components.

No warranty is guaranteed in connection with faults resulting from improper use, from modifications or repairs carried out by Manufacturer-unauthorized personnel on the module, or if the content of this user Manual is not followed.

#### 2. DESCRIPTION AND CHARACTERISTICS

#### 2.1 MODULE DESCRIPTION

The Z109REG2-1 module acquires a universal input signal, converts it to an analog format and sends it to a universal isolated output.

#### 2.2 GENERAL CHARACTERISTICS AND FEATURES

- Universal input voltage, current, thermocouple, thermoresistance, potentiometer, rheostat.
- Sensor powered by 2-wire technique: 20 VDC stabilized, 20mA max short-circuit protected.
- Measurement and re-transmission of isolated voltage or current analog output.
- DIP-switch for selecting type of input, START-END, output mode, zero elevation, scale inversion, output type (mA or V).
- Front panel indication: power on, off scale or setting error, and alarm status.
- Relay (SPST) output, programmable through a PC.
- STROBE input to activate the analog output on PLC command (alternatively to alarm contact).
- Facility for programming the following with a PC: beginning and end scale, additional input types, square root extraction, filter, burn-out, etc.
- 3-way isolation: 1500 VA.


#### 3. TECHNICAL SPECIFICATIONS


3.1 INPUT	
Voltage input:	Bipolar from 75 mV up to 20 V in 9 scales, input impedance 1 M $\Omega$ , resolution max 15 bit + sign.
Current input:	Bipolar up to 20 mA, input impedance ~50 $\Omega$ , resolution: 1 $\mu$ A.
thermoresistance (RTD) input: PT100, PT500, PT1000, NI100, KTY81, KTY84-130/-150, NTC	2, 3 or 4 wire measurement, energizing current 0.56 mA, resolution 0.1 °C, automatic detection of interruption of RTD. Resistive value for NTC< 25 kOhm. KTY81, KTY84 and NTC may be set only via software
Thermocouple input:	Type J,K,R,S,T,B,E,N; resolution: 2.5 $\mu$ V, automatic detection of TC interruption, input impedance >5 $M\Omega$
Rheostat input:	Full scale min 500 $\Omega$ , max 25 k $\Omega$ .
Potentiometer input:	Excitation voltage 300 mV, input impedance > 5 M $\Omega$ , potentiometer value from 500 $\Omega$ to 100 k $\Omega$ (with the aid of a parallel resistence equal to 500 $\Omega$ ).
Sampling frequency:	Variable from 240 sps with 11 bit resolution + sign to 15 sps with 15 bit + sign resolution (typical values).
Response time:	35 ms with 11 bit resolution, 140 ms with 16 bit resolution (measurement of voltage, current, potentiometer).

3.2 OUTPUTS	
Output:	I: 0-20 / 4-20 mA, max load resistance 600 $\Omega$ V: 0-5 V / 0-10 V / 1-5 V / 2-10 V, min load resistance 2 k $\Omega$ Resolution: 2.5 μA / 1.25 mV
Relay output (spst):	Capacity:1A-30V-7/√
Data memory:	EEPROM for all configuration data; storage time: 40 years.



MI004202-E ENGLISH 2/16





analog input



3LUT

#### **STANDARDS**

The module complies with the following standards:

EN61000-6-4 (electromagnetic emission, in industrial environment)

EN61000-6-2 (electromagnetic immunity,

in industrial environment)

EN61010-1 (safety)

#### Notes:



- Use in Pollution Degree 2 Environment

- Power Supply must be Class 2

- When supplied by an Isolated Limited Voltage and/or Limited Current power supply, a fuse rated max 2.5 A shall be installed in the field

- analog output / digital input/ output	Shall be installed in the field.						
Errors referred to maximum	Calibration	Thermal	Linearity	EMI			
measuring range:	Error	Coefficient	Error				
Voltage or current input	0.1%	0.01%/°K	0.05%	<1%			
TC Input: J, K, E, T, N	0.1%	0.01%/°K	0.2°C	<1% (1)			
TC Input: R, S	0.1%	0.01%/°K	0.5°C	<1% (1)			
TC Input: B (2)	0.1%	0.01%/°K	1.5°C	<1% (1)			
Cold junction compensation	2°C in ambient range from 0 to 50°C.						
(to TC Input)							
Potentiometer / Resistor Input	0.1%	0.01%/°K	0.1%	<1%			
Thermoresistance RTD Input:	0.1%	0.01%/°K	0.02% (se t > 0°C)	<1% (4)			
PT100, PT500, PT1000, NI100 (3)			0.05% (se t < 0°C)				
Voltage output (5)	0.3%	0.01%/°K	0.01%				

- (1) Influence of cable resistance 0.1 mV/Ohm.
- (2) Output zero if t < 250 °C.
- (3) All the values have to be calculated on the resistive value.
- (4) Influence of cable resistance 0.005%/Ohm, max 20 Ohms.
- (5) Values to be added to the errors of the selected input.

3.3 CONNECTIONS	3.3 CONNECTIONS					
USB Interface		Micro USB connector (front panel)				
3.4 POWER SUPPL	Υ.					
Supply Voltage		10-40 V <del></del> , 19-28 V → 50-60 Hz, via screw terminals: 2 – 3				
Power supply unit		Class 2				
Power consumption		1.6 W @ 24 V with output 20 mA; Max: 2.5 W				
3.5 MODULE CASE						
Case	PA6	, black color				
Dimensions	Wid	th W=17.5mm; Height H=100mm; Depth D=112mm				
Board terminals	Removable 3 way screw terminals: pitch 5.08mm, section 2.5mm <sup>2</sup>					
Protection class IP20, must be installed a protective enclosure						
3.6 ENVIRONMENTAL CONDITIONS						
Operating Temperature	-10°	°C – +60°C (UL: -10°C – +60°C)				



3.6 ENVIRONMENTAL CONDITIONS						
Humidity 30-90% at 40°C non-condensing						
Pollution degree	2 (Maximum environment pollution during operations)					
Storage Temperature	-20°C – +85°C					

## 4. PRELIMINARY INSTRUCTIONS FOR USE

The module was designed to be installed on an IEC EN 60715 rail in a vertical position.

We suggest the module installation in the lower part of the control panel.

In order to ensure best performance and longest working life module, please ensure adequate ventilation to the modules and avoid placing raceways or other objects which obstructs the ventilation slots. It's forbidden to install the module near or above heat sources.

- «Severe operating conditions» are as follows:
- High power supply voltage: >30 V<sup>--</sup>, 26 V<sup>-</sup>.
- The module supplies power to the sensor at input.
- Output used as current generator (connected to a passive module).
- If the modules are installed side by side, separate them by at least 5 mm in the following cases:
- If the panel operating temperature exceeds 45°C and at least one of the severe operating conditions exists;
- If the panel operating temperature exceeds 35°C and at least two of the severe operating conditions exist.

## 5. ELECTRICAL CONNECTIONS


#### **5.1 SAFETY MEASURES BEFORE USE**

To satisfy the electromagnetic compliance requirements:

- Use shielded cables for signal transmission;
- The cable shield must be connected to an earth wire used specifically for instrumentation;
- Avoid placing signal cables near power cables and power appliances (inverters, motors, induction ovens, etc.)

## **5.2 USB INTERFACE**

The module has a microUSB connector, you can configure it through the App and/or software. For more information please see www.seneca.it/products/z109reg2-1




## **5.3 CONNECTIONS**



Please provide the module with supply voltage < 40 V  $\rightleftharpoons$  or < 28 V  $\curvearrowright$ .


These upper limits must not be exceeded to avoid serious damage to the module.

## **5.4 POWER SUPPLY**






#### 5.5 UNIVERSAL INPUT



## 5.6 ANALOG AND RELAY OUTPUT / STROBE INPUT



 $P=500 \Omega \div 100 k\Omega$ 

- (6) Powered active output to be connected to passive inputs.
- (7) Unpowered passive output to be connected to active inputs.
  In order to select this feature please see: SETTINGS THROUGH INTERNAL JUMPERS.
- (8) As an alterntive to STROBE input. RELAY output contact normally closed, opened in event of alarm.
- (9) As an alternative to the relay output. It is optoisolated and enables the current analog output. You can use it to multiplex a PLC input on n Z109REG2.

In order to enable this input please see: SETTINGS THROUGH INTERNAL JUMPERS.

## 6. CONFIGURATION

## **6.1 INPUT SELECTION / MEASURING SCALE**

You can select the type of input by setting SW1 DIP switches placed on the side of the module. Every type of input is matched to a certain number of beginning and end scale values which can be selected through SW2 DIP switches.

The following table lists possible START and END values according to the type of input selected. The left column show the DIP-switches setting in order to select the START and END scale desired.





Note: DIP-switches must be set while the module is powered down, otherwise, the module may be damaged.

(\*)START and END set in the memory by a PC or by the programming push-buttons.

/1 2 3<sub>1</sub>4 5 6\7 8

#### SW2 DIP-switch in OFF ↓ position

Resistance / Comment										
SCA	ALE n°	Voltage			Rheostat		Current		Potentiometer	
		START	END	START	END	START	END	START	END	
	1	*(*)	(*)	(*)	(*)	(*)	(*)	(*)	(*)	
	2	0 V	100 mV	0 Ω	1 kΩ	0 mA	1 mA	0 %	40 %	
	3	400 mV	200 mV	0.5 kΩ	2 kΩ	1 mA	2 mA	10 %	50 %	
	4	1 V	500 mV	1 kΩ	3 kΩ	4 mA	3 mA	20 %	60 %	
	5	2 V	1 V	2 kΩ	5 kΩ	-1 mA	4 mA	30 %	70 %	
	6	-5 V	5 V	5 kΩ	10 kΩ	-5 mA	5 mA	40 %	80 %	
	7	-10 V	10 V	10 kΩ	15 kΩ	-10 mA	10 mA	50 %	90 %	
	8	-20 V	20 V	15 kΩ	25 kΩ	-20 mA	20 mA	60 %	100 %	
SC	ALE n°	NI100	(RTD)	PT100	(RTD)	PT500	(RTD)	PT1000	(RTD)	
30/	\ II	START	END	START	END	START	END	START	END	
	1	(*)	(*)	(*)	(*)	(*)	(*)	(*)	(*)	
	2	-50 °C	20 °C	-200 °C	50 °C	-200 °C	0 °C	-200 °C	0 °C	
	3	-30 °C	40 °C	-100 °C	100 °C	-100 °C	50 °C	-100 °C	50 °C	
	4	-20 °C	50 °C	-50 °C	200 °C	-50 °C	100 °C	-50 °C	100 °C	
	5	0 °C	80 °C	0 °C	300 °C	0 °C	150 °C	0 °C	150 °C	
	6	20 °C	100 °C	50 °C	400 °C	50 °C	200 °C	50 °C	200 °C	
	7	30 °C	150 °C	100 °C	500 °C	100 °C	300 °C	100 °C	300 °C	
	8	50 °C	200 °C	200 °C	600 °C	150 °C	400 °C	200 °C	400 °C	
SC	ALE n°	Thermo			couple K	Thermod	couple R	Thermocouple S		
30/	ALEII	START	END	START	END	START	END	START	END	
	1	(*)	(*)	(*)	(*)	(*)	(*)	(*)	(*)	
	2	-200 °C	100 °C	-200 °C	200 °C	0 °C	400 °C	0 °C	400 °C	
	3	-100 °C	200 °C	-100 °C	400 °C	100 °C	600 °C	100 °C	600 °C	
	4	0 °C	300 °C	0 °C	600 °C	200 °C	800 °C	200 °C	800 °C	
	5	100 °C	400 °C	100 °C	800 °C	300 °C	1000 °C	300 °C	1000 °C	
	6	200 °C	500 °C	200 °C	1000 °C	400 °C	1200 °C	400 °C	1200 °C	
	7	300 °C	800 °C	300 °C	1200 °C	600 °C	1400 °C	600 °C	1400 °C	
	8	500 °C	1000 °C	500 °C	1300 °C	800 °C	1750 °C	800 °C	1750 °C	
	A.I. = 0	Thermo	couple T	Thermoco	Thermocouple B (#)				Thermocouple N	
SC	ALE n°	START	END	START	END T	START	END	START	END	
	1	(*)	(*)	(*)	(*)	(*)	(*)	(*)	(*)	
	2	-200 °C	50 °C	0°C	500 °C	-200 °C	50 °C	-200 °C	200 °C	
	3	-100 °C	100 °C	500 °C	600 °C	-100 °C	100 °C	-100 °C	400 °C	
	4	-50 °C	150 °C	600 °C	800 °C	0 °C	200 °C	0 °C	600 °C	
	5	0 °C	200 °C	700 °C	1000 °C	100 °C	300 °C	100 °C	800 °C	
	6	50 °C	250 °C	800 °C	1200 °C	150 °C	400 °C	200 °C	1000 °C	
	7	100 °C	300 °C	1000 °C	1500 °C	200 °C	600 °C	300 °C	1200 °C	
						<u> </u>				
	8	150 °C	400 °C	1200 °C	1800 °C	\400 °C	800 °C	500 °C	1300 °C	

**LEGEND** 

**1** 

ON

₽₩

OFF

**♦** (#) Output = 0 (zero) when t < 250°C.



	SW1: INPUT SELECTION								
PC	POSITION INPUT POSITION INPUT							INPUT	
1	2	3	4	TYPE	1	2	3	4	TYPE
				V					Tc K
				$\Omega$ / Rheostat					Tc R
				mA					Tc S
				NI100					Tc T
				PT100					Tc B
				PT500					Tc E
				PT1000					Tc N
				Tc J					Potentiometer

SW2: START e END						
POSITION	START	POSITION	END			
1 2 3	SCALE n°	4 5 6	SCALE n°			
	1		1			
	2		2			
	3		3			
	4		4			
	5		5			
	6		6			
	7		7			
	8		8			

#### 6.2 CUSTOM START AND END SETTINGS

The START and END push-buttons under the SW2 DIP-switch group allow you to set a custom beginning and end point within the pre-set DIP-switch scales. To do this it is necessary to use a suitable signal generator or calibrator to be able to furnish the desired beginning and end scale values. The procedure:

- 1. Set the DIP switches for the type of input.
- 2. Set the DIP switches for START and END settings that cover the custom range.
- 3. Power up the module.
- 4. Use a calibrator or simulator to supply the signal you wish to measure.
- 5. Set the required START value on the calibrator (or other instrument).
- 6. Press the START push-button for at least 3 sec. The green LED on the front panel flashes to indicate the value has been stored.
- 7. Repeat steps 4 and 5 for the required END value.
- 8. Power off the module.
- 9. Set the group SW2 DIP switches corresponding to the START and END settings to the OFF position.

The module is now configured for the required start and end scale.

In order to re-program it (e.g. for a different type of input or range) repeat the entire procedure.

#### 6.3 OUTPUT SELECTION

SW2 group DIP-switches 7 and 8 enable you to set the output with or without zero elevation and/or as a normal or reversed output. The SW3 DIP-switch group enables you to select the output type. Note:The DIP-switches must be set while the module is powered down, avoiding electrostatic discharge, otherwise the module may be damaged.

SW2: SCALE AND MODE OUTPUT							
POSITION	OUTPUT	POSITION	OUTPUT				
7 8	RANGE	7 8	MODE				
■ X	0-20mA / 0-10V	Χ 🖥	NORMAL				
₽ X	4-20mA / 2-10V	ΧĒ	REVERSE				

SW3: OUTPUT TYPE						
POSITION	OUTPUT	POSI	TION	OUTPUT		
1 2	TYPE 1 2			TYPE		
	VOLTAGE 🖥 🖺			CURRENT		
LEGEND						

#### 6.4 CONFIGURATION USING A PC


By using a PC and EASY SETUP software, it is possible to set other normally fixed parameters in addition to start and end scale:

Additional input types: digital filter (normally disabled), square root extraction (normally disabled), negative burn-out (normally positive), alarm (normally set as error signaling), start and end scale of the analog output, value of the analog output in case of error, rejection programmable for 50 or 60 Hz power frequency (normally set to 50 Hz), sampling frequency/resolution (normally set to 15 sps/16 bit), 3 or 4 wires measure for thermal resistance (normally set to 3 wires) and action of the digital output alarm in case of fault. Instructions for setting and the connection cable are supplied with the software (this must be requested as an accessory item).




MI004202-E ENGLISH 7/16

#### **6.5 JUMPER POSITIONS**



# SETTINGS THROUGH INTERNAL JUMPERS

#### **ACTIVE / PASSIVE OUTPUT**



## **RELAY OUTPUT / STROBE INPUT**

Relay	Output	
J3 🗓	J1 🗓	

STROBE	Input
J3 🔋 J1	

6.6 LED INDICATIONS ON THE FRONT PANEL		
LED	LED STATE	LED MEANING
PWR	ON	Power supply presence
Green	Blinking frequency: 1 flash/sec	Out of Range, Burn Out, or Internal failure
	Blinking frequency: ≈ 2 flashes/sec)	DIP-switch setting error
FAIL Yellow	ON	Alarm event (open relay contact)
	OFF	No Alarm (closed relay contact)

7. PURCHASE ORDER CODE			
ORDER CODE	SPECIFICATIONS		
CU-A-MICROB	USB-microUSB 1 meter communication cable.		
CU-A-MICRO-OTG	Adapter cable for Android smartphone.		

8. MODULE LAYOUT FRONTAL PANEL	MODULE DIMENSIONS
1 2 3 4 5 6 S PWRI FAIL ALARM	17.5 mm    17.5 mm   17.5
Z109REG2 7 8 9 10 11 12	21008EGZ 7 8 9 10 11 12

## 9. DECOMMISSIONING AND DISPOSAL



Disposal of Electrical & Electronic Equipment (Applicable throughout the European Union and other European countries with separate collections programs). This symbol, found on your product or on its packaging, indicates that this product should not be treated as household waste when you wish to dispose of it. Instead, it should be handed over to an applicable collection point for the recycling of electrical & electronic equipment. By ensuring this product is disposed of correctly, you will help prevent potential negative consequences to the environment and human health, which could otherwise be caused by inappropriate disposal of this product. The recycling of materials will help to conserve natural resources. For more detailed information about the recycling of the product, please contact your local city office, waste disposal service of the retail store where you purchased this product.



MI004202-E ENGLISH 8/16